

INFORMATION DATA SHEET: Verdura X Strand Woven Bamboo **Date: September 2017**

1 COMPANY DETAILS

Company: Homemirus Pty Ltd trading as Preference Floors
Address: Unit A/31 Sturt Street Smithfield NSW 2164
Telephone: 02 9738 1188
Facsimile: 02 9738 1199

2 PRODUCT IDENTIFICATION

Verdura X Brand, 142 x 14mm Strand Woven Bamboo

3 HEALTH HAZARD DATA

Formaldehyde Emission from newly produced Strand Woven Bamboo wear layer

4 RESULT AND CONCLUSIONS

Based on the test outcome undertaken by SGS Standards Testing Services on 16 July 2015 for strand woven bamboo as used in the Verdura X wear layer We can confirm a test of; **0.09, which provides an outcome of E1.** This level falls within the E1 limits recommended by the World Health Organisation (WHO).

Summary result;			
Test Item(s)	<u>Unit</u>	<u>MDL</u>	<u>001</u>
Formaldehyde	ug/mL	0.05	0.09

Disclaimer: Homemirus Pty Ltd trading as Preference Floors has used its reasonable endeavors to ensure the accuracy and reliability of the information contained herein and, to the extent permitted by law, will not be liable for any inaccuracies, omissions or errors in this information nor for any actions taken in reliance on this information. Products must be installed in accordance with relevant installation recommendations and industry best practices.

© Homemirus Pty Ltd trading as Preference Floors. Date of publication September 2017.

INFORMATION DATA SHEET: Verdura X Strand Woven Bamboo Date: September 2017

Copy documents SGS Test results.

SGS


Test Report No. SHAMLP1512980201 Date: 16 Jul 2016 Page 1 of 3

Reference Floor:
UNI-A31-39 Stun St Smithfield NSW 2164 Australia


The following sample(s) was/were submitted and identified on behalf of the client as: Strand Woven Bamboo

SGS Job No.: SHN1507029292SPC-041
Material and Mark: Ventura
Product Specification: 1860x136x14mm
Date of Sample Received: 03 Jul 2016
Testing Period: 03 Jul 2016 - 16 Jul 2016
Test Requested: Selected test(s) as requested by client.
Test Method: Please refer to next page(s).
Test Result: Please refer to next page(s).

Signed for and on behalf of
SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.



Shief C
Approved Signatory



Member of the SGS Group (SGS SA)

SGS

Test Report No. SHAMLP1512980201 Date: 16 Jul 2016 Page 2 of 3

Test Result:

Test Part Description:

Specimen No. SGS Sample ID Description
DN1 SH415-129802-001 Nature board with transparent paint


Remarks:
(1) 1 mg/kg = 0.0001%
(2) MDL = Method Detection Limit
(3) ND = Not Detected (< MDL)
(4) "-" = Not Regulated

Formaldehyde Emission


Test Method: With reference to ASTM D 5682 - 00 (Reapproved 2006), analysis was performed by UV-Vis.

Test Item(s)	Unit	MDL	ND
Formaldehyde	µg/mL	0.05	0.09

Signed for and on behalf of
SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.



Shief C
Approved Signatory



Member of the SGS Group (SGS SA)

SGS

Test Report No. SHAMLP1512980201 Date: 16 Jul 2016 Page 2 of 3

Test Result:

Test Part Description:

Specimen No. SGS Sample ID Description
DN1 SH415-129802-001 Nature board with transparent paint


Remarks:
(1) 1 mg/kg = 0.0001%
(2) MDL = Method Detection Limit
(3) ND = Not Detected (< MDL)
(4) "-" = Not Regulated

Formaldehyde Emission


Test Method: With reference to ASTM D 5682 - 00 (Reapproved 2006), analysis was performed by UV-Vis.

Test Item(s)	Unit	MDL	ND
Formaldehyde	µg/mL	0.05	0.09

Signed for and on behalf of
SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.



Shief C
Approved Signatory




Member of the SGS Group (SGS SA)

SGS

Test Report No. SHAMLP1512980201 Date: 16 Jul 2016 Page 3 of 3


Sample photo:




SHAMLP1512980201

SGS authenticates the photo on original report only
*** End of Report ***

Signed for and on behalf of
SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd.



Shief C
Approved Signatory



Member of the SGS Group (SGS SA)